


APPENDIX H  
SANITARY SEWER OVERFLOWS  
LOCATION MAP



# Sewer Overflows - City of Diamond Bar

## 2008 - 2012

2008	ID	DATE	DESCRIPTION	CAUSE	EST_GAL	MMS_FID	DUR_HRS
	1	2/20/2008	21015 Brea Canyon Rd.	Roots	300	2348-0583	39
	2	4/8/2008	990 Diamond Bar Blvd./Highland Valley Rd.	Roots & Grease	400	2389-0273	1.5
	3	8/5/2008	2110 S Indian Creek Rd./Blaze Trail	Force Main Broken	1950	2392-PS	15
	4	10/10/2008	2110 S Indian Creek Rd./Blazing Trail	Power Outage	400	2392-0208	2.5
	5	11/24/2008	1459 S Longview Dr./Grand Ave	Power Failure	75	2434-0104	1
	6	11/24/2008	1459 S Longview Dr./Grand Ave	Power Failure	75	2434-0106	1
2009	ID	DATE	DESCRIPTION	CAUSE	EST_GAL	MMS_FID	DUR_HRS
	1	1/29/2009	2909 Steeple Chase Lane/Shadow Canyon	Roots	200	2392-0022	2
	2	11/14/2009	21418 Fountain Springs Rd/Diamond Bar Blvd.	Lost Power	3000	2392-0124	1
2010	ID	DATE	DESCRIPTION	CAUSE	EST_GAL	MMS_FID	DUR_HRS
	1	2/1/2010	1466 Spruce Tree/Mountain Latural	Root & Grease	1000	2391-0465	2
	2	6/6/2010	23159 Rio Lobos Rd/Diamond Bar Blvd.	Heavy Grease	200	2390-0355	2.5
	3	6/28/2010	2375 Presado Dr./Laurel Rim Dr.	Roots	300	2391-0120	2
	4	10/2/2010	145 South Longview Dr/Grand Ave (Pump Station Failure)	Electric system malfunction	500	SMPS00760	0.5

2011	ID	DATE	DESCRIPTION	CAUSE	EST_GAL	MMS_FID	DUR_HRS
	1	4/15/2011	2434 Castle Rock Rd. /lost River Dr.	Roots & Grease	300	2392-0143	1
	2	4/13/2011	2100 Chestnut Creek Rd. / Tierra Loma Rd.	Heavy Roots	75	2391-0115	1.5
2012	ID	DATE	DESCRIPTION	CAUSE	EST_GAL	MMS_FID	DUR_HRS
	1	5/10/2012	Pioneer Rd (Indian Creek Pump Station)	Broken force main	1635	SMPS00630	0.5
	2	7/23/2012	23655 Maple Spring Dr./Rancheria Rd.	Heavy Roots	6500	2433-0033	22.5
	3	11/4/2012	2350 PRESADO DR / PATHFINDER	Roots	3000	2391-0122	2.5
	4	11/8/2012	2147 CHESTNUT CREEK RD. / TIERRA LOMA DR.	Roots	200	2391-0115	1.5
	5	11/15/2012	345 EL ENCINO DR. / DEL SOL LN.	Heavy Roots & Grease	50	2432-0103	4



